



## **IFB ADDENDUM #1**

To: All Bidders

From: Rita V. Brousseau, Chief Procurement Officer

Date: June 2, 2021

Re: QSP 2021-13A Flooring & Install @ Learning Zone

---

This Addendum modifies and forms a part of the Bid Set documents dated May 19, 2021.

This Addendum consists of the following: Two pages (addendum & Revised Form for General Bid.

Where any items called for in the bid documents are supplemented here, the supplemental requirements shall be considered as added thereto. Where any original item is amended, voided, or superseded here, the other provisions of such items not specifically amended, voided, or superseded shall remain in effect.

### **Answers to bidder's questions:**

1. **Question:** The photos of the areas to be tiled show that existing Resilient Base, either vinyl or rubber, was removed. Should we include supplying and install new base or is a wood base being used?  
**Answer:** Contractor shall supply and install approximately 300 linear feet of 4", 0.125 thick curved vinyl wall base. Color TBD.

All other portions of the Contract Documents remain **unchanged**.



**NOTE TO ALL BIDDERS: YOU MUST ACKNOWLEDGE RECEIPT OF ALL ADDENDA ON YOUR BID SUBMISSION FORM WHERE INDICATED OR INCLUDE A COPY OF ADDENDA IN YOUR BID SUBMISSION.**