



## **QSP ADDENDUM #2**

To: All Bidders

From: Rita V. Brousseau, Chief Procurement Officer

Date: May 24, 2023

Re: QSP 2023-12 Hale Street Electrical and Carpentry

---

This Addendum modifies and forms a part of the Bid Set documents dated May 10, 2023.

This Addendum consists of the following: One (1) typed page.

Where any items called for in the bid documents are supplemented here, the supplemental requirements shall be considered as added thereto. Where any original item is amended, voided, or superseded here, the other provisions of such items not specifically amended, voided, or superseded shall remain in effect.

THE NUMBER OF THIS ADDENDUM MUST BE ENTERED IN THE APPROPRIATE SPACE PROVIDED ON "GENERAL BID FORM."

### **ADD to the original Scope of Work:**

- Remove abandoned aluminum SE cable and supports from loadcenter to crawlspace.
- Existing loadcenter feeder (spliced SE-R cable conductors) that are existing to remain.

END OF ADDENDUM #2